



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: ERA-2000-0007-REV1

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory 11th August 2020. Classification of reaction to fire has been carried out in accordance the standard:

EN 13501-1:2018

“PIR Filled Roof Panel – 100 mm”

Fire behaviour		Smoke production		Flaming droplets
B	-	s	1	, d 0

Flammability Classification*

Hardly inflammable

*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: **TEKNOPANEL ÇATI VE CEPHE PANELLERİ ÜRETİM SAN. VE TİC. A.Ş.**
Mersin-Tarsus OSB 7. Cadde No:10 33443 Akdeniz, Mersin / TURKEY

Manufactured by: **TEKNOPANEL ÇATI VE CEPHE PANELLERİ ÜRETİM SAN. VE TİC. A.Ş.**
Sakarya 2. OSB 1. Cad. No: 1, 54300, Hendek, Sakarya / TURKEY

Ali BAYRAKTAR
Laboratory Manager
17.11.2021



This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: ERA-20-127-REV1.